



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on June 8, 2018.

West Penetone Inc.
10900 Secant
Montreal, Québec H1J 1S5
Canada
800-361-8927
514-355-4660

Facility: Montreal, Québec, Canada

Chemical/ Trade Designation	Function	Max Use
Chlorine Dioxide Ingredients [1] [CL]		
Dichlorosan A	Bactericide	10 mg/L
Dichlorosan B	Bactericide	10 mg/L

[1] Component A and component B are to be mixed following manufacturer's use instructions to produce a 0.0001% (1 ppm) chlorine dioxide solution.

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.